

Plant Effluent
Phos as P, mg/L

	09/16/14	2.53
	09/17/14	2.95
Hauled Sludge	09/18/14	
	09/19/14	
	09/20/14	
	09/21/14	
	09/22/14	2.16
	09/23/14	2.03
	09/24/14	2.12
	09/25/14	1.68
	09/26/14	1.59
	09/27/14	
	09/28/14	
	09/29/14	1.28
	09/30/14	1.09
	10/01/14	
	10/02/14	
	10/03/14	
	10/04/14	
	10/05/14	
	10/06/14	2.08
	10/07/14	2.91

06/01/15	1.76
06/02/15	1.82
06/03/15	2.19
06/04/15	1.97
06/05/15	
06/06/15	
06/07/15	

Hauled Sludge	06/08/15	1.58
	06/09/15	1.49
	06/10/15	1.46
	06/11/15	1.49
	06/12/15	1.51

	06/13/15	
	06/14/15	
Added Soda Ash Only	06/15/15	1.59
	06/16/15	1.63
	06/17/15	
	06/18/15	
	06/19/15	
	06/20/15	
	06/21/15	

Additional Delpak Location (Polishers) @ 75%	06/22/15	1.63
	06/23/15	1.60
	06/24/15	1.94
Added Soda Ash during Application at second point.	06/25/15	1.50
	06/26/15	1.28

	06/27/15	
	06/28/15	
	06/29/15	
	06/30/15	1.27
	07/01/15	0.89